


NOZZLE SCHEDULE

MARK	SIZE	PROJECTION	TYPE	RATING	ELEVATION	ORIENTATION	WELD DETAIL	SERVICE/REMARK
N1	2 in	3 3/4"	S/O FLG.	CL-150	11'-9"	90°	VII, Xa	OVERFLOW
N2	12 in	6"	FLG NOZZLE W/VORTEX BREAKER	CL-150	1'-3"	270°	VII, Xa	PUMP SUCTION
N3	3/4 in	CENTER	CPLG.	CL-3000	6"	180°	IXa	PRESSURE TRANSDUCER
N4	2 in	CENTER	CPLG.	CL-3000	10'-6"	180°	IXa	WATER MAKEUP
N5	1 in	CENTER	CPLG.	CL-3000	11'-7"	0	IXa	LEVEL COLUMN, HIGH
N6	1 in	CENTER	CPLG.	CL-3000	0'-6"	0	IXa	LEVEL COLUMN, LOW
N7	2 in	CENTER	CPLG.	CL-3000	0'-3"	90°	IXa	DRAIN
N8	12 in	-	S/O FLG	CL-150	-	0°		CWR PIPE

DESIGNED BY - DATE: CMO - 4/5/2023	USEMCO USEMCO INCORPORATED P.O. BOX 550 (608) 372-5911 TOMAH WI. 54660	
DRAWN BY - DATE: JAB - 4/5/2023		
CHECKED BY - DATE: CMO - 4/5/2023	DESCRIPTION: 4,500 GALLON SUMP TANK	
SCALE: NTS	DWG. NO.: 99641	
SHEET 2 OF 4		